SAINT PAUL REGIONAL WATER SERVICES

PHYSICAL AND CHEMICAL ANALYSIS OF WATER

Oct-13

All results are in parts per million & Samples Measured are Dissolved Ions

PHYSICAL WATER QUALITY

	Reporting Limit	EFFLUENT
Color (Color Units)	4	<4
Loss Ignition (ppm)	84	<84
Non-Volatile Salts (ppm)	84	96
Temperature (^{0}C)	0.02	16
Total Dissolved Solids (ppm)	56	175
Turbidity (NTU)	0.025	<0.025

CHEMICAL WATER QUALITY

	Reporting Limit	EFFLUENT
Alkalinity-Total (ppm as $CaCO_3$)	0.40	49
Carbonate Hardness (ppm as $CaCO_3$)	0.40	49
Dissolved Oxygen (ppm)	1.2	8.5
Hydrogen Ion-pH	0.04	9.05
Non-Carbonate Hardness (ppm)	0.40	30
Total Hardness (ppm as $CaCO_3$)-EDTA method	0.40	79
Total Organic Carbon (ppm as C)	0.40	4.01

Total Hardness (grains/Gal as $CaCO_3$)-EDTA method is 4.62 grains/Gal

CHEMICAL WATER QUALITY - INORGANIC NONMETALS

	Reporting Limit	EFFLUENT
Ammonia Nitrogen (ppm as N)	0.030	0.770
Chloride-Cl (ppm as Cl^{-1})	8	35
Chlorine Residual (ppm Cl as Cl_2)	0.09	3.57
Fluoride-F (ppm as F^{-1})	0.08	0.85
Nitrate, Nitrite Nitrogen (ppm as N)	0.202	<0.202
Sulfur-S (ppm as S)	2.7	<2.7
Sulfide-S^{2-} (ppm as S^{2-})	0.020	<0.020
Total Phosphorus-P (ppm as P)	0.020	<0.020
Total Nitrogen-N (ppm as N)	0.008	0.916

CHEMICAL WATER QUALITY - METALS

	Reporting Limit	EFFLUENT
Aluminum-Al (ppm as Al)	0.006	0.008
Arsenic-As (ppm as As)	0.006	<0.006
Cadmium-Cd (ppm as Cd)	0.003	<0.003
Calcium-Ca (ppm as Ca)	0.40	19
Copper-Cu (ppm as Cu)	0.050	<0.050
Hexavalent Chromium (ppm as Cr^{6+})	0.040	<0.040
Iron-Fe (ppm as Fe)	0.050	<0.050
Lead-Pb (ppm as Pb)	0.006	<0.006
Magnesium-Mg (ppm as Mg)	0.40	8
Manganese-Mn (ppm as Mn)	0.050	<0.050
Silicon-Si (ppm as Si)	0.84	3.07
Sodium-Na (ppm as Na)	0.079	18.0
Zinc-Zn (ppm as Zn)	0.050	<0.050