

DEPARTMENT OF SAFETY & INSPECTIONS Robert Kessler, Director

8 East Fourth Street, Suite 200

Telephone: 651-266-8989

Saint Paul, MN 55101

CODE ENFORCEMENT POLICY #2-2

May 10, 2010

TO: Fire Inspection Staff

FROM: Fire Marshal Steve Zaccard

SUBJECT: Open Burning Requirements - REVISED

Open burning is permitted under the following conditions:

RECREATIONAL FIRES

- 1. Maximum fuel area of 3 feet in diameter and 2 feet high.
- 2. No fire permit is required for a recreational fire.
- 3. No burning for disposal. No rubbish, paper products or construction materials can be burned.
- 4. Fires that are not contained in an approved burning appliance must be at least 25 feet from a building or combustible materials.
- 5. As an alternate method of compliance, fires that ARE CONTAINED in an approved container must be at least 15 feet from building or combustible material.
- 6. Any conditions which could cause a fire to spread to within 25 feet of a building shall be eliminated prior to ignition.
- 7. The means shall be provided to extinguish the fire. This can include buckets, shovels, garden hoses, or a minimum 4-A fire extinguisher.
- 8. Fires shall be constantly attended by a person knowledgeable in the use of the fire extinguishing equipment provided.

9. The fire department may order the fire to be discontinued if, in our opinion, the fire constitutes a hazardous condition or produces obnoxious smoke or odors that may cause a public nuisance

OPEN BURNING

Open burning requires a fire permit from the Department of Safety & Inspections.

- 1. Open Burning can be used for disposal, except that paper products and materials that may produce obnoxious smoke and odors cannot be burned.
- 2. Prior to ignition, the fire department must be notified at 651-224-7371.
- 3. Burning shall not be conducted within 50 feet of a building or other combustible material.
- 4. Burning may be conducted <u>within 25 feet of a building or other combustible material if the pile size</u> is no more than 3 feet in diameter and 2 feet high.
- 5. Burning may be conducted <u>within 15 feet</u> of a building or other combustible materials if the burning takes place solely within an approved burning appliance.
- 6. Any conditions which could cause a fire to spread to within 50 feet of a building shall be eliminated prior to ignition.
- 7. The means shall be provided to extinguish the fire. This includes buckets, shovels, garden hoses, or a minimum 4-A fire extinguisher.
- 8. Fires shall be constantly attended by a person knowledgeable in the use of the fire extinguishing equipment provided.
- 9. The fire department may order the fire to be discontinued if, in our opinion, the fire constitutes a hazardous condition or produces obnoxious smoke or odors that may cause a public nuisance.

For permits or questions, please call the Dept. of Safety and Inspections at 651-266-8989. Have fun and BE CAREFUL with your fire!

Issued 2/28/86 Latest Revision 5/10/10