

# SAINT PAUL REGIONAL WATER SERVICES

## PHYSICAL AND CHEMICAL ANALYSIS OF WATER

### May '14

All results are in parts per million & Samples Measured are Dissolved Ions

#### PHYSICAL WATER QUALITY

	Reporting Limit	EFFLUENT
Color (Color Units)	4	<4
Loss Ignition (ppm)	84	93
Non-Volatile Salts (ppm)	84	<84
Temperature (°C)	0.02	10
Total Dissolved Solids (ppm)	56	173
Turbidity (NTU)	0.025	0.027

#### CHEMICAL WATER QUALITY

	Reporting Limit	EFFLUENT
Alkalinity-Total (ppm as CaCO <sub>3</sub> )	0.40	50
Carbonate Hardness (ppm as CaCO <sub>3</sub> )	0.40	50
Dissolved Oxygen (ppm)	1.2	11.0
Hydrogen Ion-pH	0.04	9.01
Non-Carbonate Hardness (ppm)	0.40	30
Total Hardness (ppm as CaCO <sub>3</sub> )-EDTA method	0.40	80
Total Organic Carbon (ppm as C)	0.40	4.99

**Total Hardness (grains/Gal as CaCO<sub>3</sub>)-EDTA method is 4.68 grains/Gal**

#### CHEMICAL WATER QUALITY - INORGANIC NONMETALS

	Reporting Limit	EFFLUENT
Ammonia Nitrogen (ppm as N)	0.030	0.896
Chloride-Cl (ppm as Cl <sup>-1</sup> )	8	39
Chlorine Residual (ppm Cl as Cl <sub>2</sub> )	0.090	3.50
Fluoride-F (ppm as F <sup>-1</sup> )	0.08	1.14
Nitrate, Nitrite Nitrogen (ppm as N)	0.202	0.399
Sulfur-S (ppm as S)	2.7	8.3
Sulfide-S <sup>2-</sup> (ppm as S <sup>2-</sup> )	0.020	<0.020
Total Phosphorus-P (ppm as P)	0.025	<0.025
Total Nitrogen-N (ppm as N)	0.10	1.31

#### CHEMICAL WATER QUALITY - METALS

	Reporting Limit	EFFLUENT
Aluminum-Al (ppm as Al)	0.006	0.009
Arsenic-As (ppm as As)	0.006	<0.006
Cadmium-Cd (ppm as Cd)	0.003	<0.003
Calcium-Ca (ppm as Ca)	0.40	19
Copper-Cu (ppm as Cu)	0.050	<0.050
Hexavalent Chromium (ppm as Cr <sup>6+</sup> )	0.040	<0.040
Iron-Fe (ppm as Fe)	0.050	<0.050
Lead-Pb (ppm as Pb)	0.006	<0.006
Magnesium-Mg (ppm as Mg)	0.40	8
Manganese-Mn (ppm as Mn)	0.090	<0.090
Silicon-Si (ppm as Si)	0.84	3.88
Sodium-Na (ppm as Na)	0.079	23.70
Zinc-Zn (ppm as Zn)	0.050	<0.050