



RESIDENTIAL GARAGE WIRING

Revised July, 2023

This handout attempts to answer the questions asked most often by homeowners. The information contained in this is NOT all you need to know to do your project, it is only to assist you in the project. The wiring must be done to the standards of the latest state-adopted National Electrical Code (2023 NEC). New garage wiring is required to meet NEC 210.11(C)(4), this section requires the receptacles, in each vehicle bay, in a garage to be supplied by a 20 amp branch circuit by themselves, no other outlets. This change will require, at minimum, a multi-wire branch circuit to a new detached garage. Bulletin 2018-01 has been revised to clarify the change to the requirements for the branch circuit feeding a new replacement garage. An Electrical Permit is required for all new, modified, and/or repaired circuits in a garage. In a single-family residence, the owner-homesteader may obtain the permit to do the work his/herself. For other residential occupancies, with a few small exceptions, an electrical contractor must be hired to do the work and obtain the permit.

Some basic rules:

1. Most homeowners choose to run the electrical underground. The two most popular methods are direct-burial cable or PVC (plastic) conduit. Direct burial cable is designated as UF (**U**nderground **F**eeder) or for larger sizes, USE (**U**nderground **S**ervice **E**ntrance). These cables may be buried directly in the ground at 24 inches below grade. They must have mechanical protection such as PVC conduit wherever they are closer than 24" below grade. The most common points that this happens is where the run is brought up above grade to enter the house and garage. PVC conduit is the other popular method used. The PVC **MUST** be approved as electrical conduit- other types such as PVC plumbing pipe is not acceptable. Standard insulated conductors may then be pulled inside the PVC. These single conductors must have a "W"(for water-resistant) in their designation that is stamped on the jacket of the wire. Examples of this designation would be: THWN, XHHW, etc. Type NM Cable cannot be run inside underground conduit- the outer jacket of the NM is not rated for wet locations. PVC conduit may be buried at 18 inches below grade. (This is measured to the top of the conduit, so the trench will have to be deeper than 18"). **All trenches must be inspected** for proper depth by the Electrical Inspector listed on the permit before the trench can be covered up.

2. A disconnect must be installed in a detached garage to shut off all power to the building. This disconnect must be immediately inside the garage at the entrance point of the feed from the house. If you are using a multi-circuit panelboard in the garage and have no more than 6 breakers in the panel, these breakers may be used as the disconnecting means. More than 6 breakers, you must have a main breaker in the panelboard. If you are running a multi-wire 20 ampere branch circuit from the house to feed a minimum number of lights and outlets, a separate 2-pole 20 amp switch must be used as a disconnect. This switch must be the first device

that is on the circuit once it enters the garage, and it may be used only as a disconnect-it cannot be used to control lights or other equipment. This disconnect must be marked as the disconnecting means on its box cover. (See figure 1 on diagram pages)

3. Non-Metallic Cable (NM Cable) may be used inside the garage. It must be drilled through the studs, not run on the face of them. Also, never drill through factory roof trusses, run the NM Cable on the top edge in a location it will not be damaged. If you run NM Cable horizontally, such as between boxes on a wall, if the wall is not enclosed by sheetrock the cable cannot be run horizontally lower than 8 feet above the floor, unless an equivalent means of protection is installed. As an example, to run between two boxes on an unfinished wall, you would have to run the NM Cable up from one box to a height of 8' or more, run horizontally until you are even with the other box, and then run back down to the second box. This method is required because there is a greater chance of physical damage to the cable by hanging tools, etc on the horizontal runs if they are lower than 8 feet. Other installation requirements in the National Electrical Code, including Article 334 also apply.

4. All 125-volt through 250-volt single-phase receptacles installed in garages must be protected by a readily accessible Ground Fault Circuit Interrupter (GFCI), including any for garage door openers or specific appliances [NEC 210.8(A)]. There are two forms of GFCI protective devices. You may use a tamper-resistant receptacle-type GFCI protective device, or a breaker style GFCI protective device. Both devices are designed to be installed at the beginning of the circuit to be protected, and several standard tamper-resistant outlets may be protected “downstream” by one GFCI outlet. See the manufacturer's instructions for details. On a GFCI, the line is the power in and the load is the power out to other receptacles. All 15- and 20-ampere, 125-volt through 250-volt nonlocking-type receptacles, below 5 ½ ft., must be the tamper-resistant type (NEC.406.12). “Tamper-Resistant” receptacles are designed with a “shutter” over the slots so only a standard cord cap (plug) can be inserted. Add-on plug covers are not acceptable. Any receptacles on the exterior of the garage must be tamper-resistant, GFCI-protected and “weather resistant” (there will be a “WR” visible on the face of the receptacle). Exterior receptacles will also need an “extra-duty” in-use (bubble) cover where exposed to direct rain [NEC 406.9(B)].

5. The National Electrical Code allows either a single multi-wire branch circuit or a feeder(s) from the house to the detached garage. No multiple circuits between buildings are allowed.


6. If a multi-wire branch circuit with a grounding conductor (either green or bare and attached to the grounding system in the house) is run from the house to the detached garage, no ground rods are required at the garage (see Figure 1). For feeders from the house to the garage, two 8-foot ground rods must be driven at least 6 ft apart outside the garage. An equipment grounding conductor is required with the feeder. When a feeder is supplying the garage, a grounding electrode is required at the garage. If there is no existing grounding electrodes at the garage, two ground rods shall be installed and connected to the equipment grounding bar in the garage panel (see Figure 2). These two ground rods may be driven right outside the garage at least 6 ft apart, and a #6 copper ground wire attached to them. If the wire is subject to physical damage



on the outside or inside of the garage, it must be protected by conduit. 1/2-inch PVC is usually the easiest method of protection. The #6 wire must be attached to the grounding system for the electrical in the garage.

7. The minimum wiring required in a detached garage that has electricity would include: A multi-wire circuit from the house, and 2-pole disconnecting means at the garage (one 20 amp circuit for the required receptacles, this circuit shall have no other outlets, and the other circuit for the lights and other equipment); A switch at the service [human] door to control a light inside the structure; and a switch controlled light outside the garage service door. Vehicular doors of a garage are exempt from any lighting requirements. A minimum of one GFCI- protected readily accessible receptacle, at or below 5 ½ ft., in a one car garage is also required. That minimum is increased for each car space/vehicle bay.

8. If an outlet(s) is installed for the purpose of charging electric vehicles it shall be supplied by a separate circuit. This circuit shall have no other outlets.

Again, please be aware that these are NOT all the requirements for wiring a garage; they are the questions that we are asked most often. If you have other questions after consulting the wiring books available, call the Electrical Inspector for your area. In Saint Paul, they can be reached at (651)266-9003 between 7:30 and 9:00am Monday through Friday.





Revised: 07/2023