



**NIPPLE THREAD**

Threads Per Inch .....	6
Nom Major Diameter .....	5.531
Max Major Diameter .....	5.541
Min Major Diameter .....	4.491
Max Pitch Diameter .....	5.445
Min Pitch Diameter .....	5.427
Max Minor Diameter .....	5.337

NOTE: Waterous Company Code No. TP60517 or equivalent

DR. <i>LJP</i> DATE. 01/13/2020
CH. <i>MGA</i>
APPROVED <i>DJS</i>

**SAINT PAUL REGIONAL WATER SERVICES**  
CITY OF ST. PAUL, MN

**SAINT PAUL STANDARD THREAD**

STANDARD  
PLATE

**D-4**