



TYPE A TRENCH TO BE CONSIDERED STANDARD TRENCH

TYPE B TRENCH TO BE IMPLEMENTED IN THE FOLLOWING CASES:

- BASE MATERIAL IS OR CONTAINS ROCK(S)
- WET CONDITIONS
- FLEXIBLE PIPE (HDPE, PEX, PVC, ETC.)
- UNSUITABLE/UNSTABLE SOILS

SPRWS TO MAKE FINAL DETERMINATION OF TRENCH TYPE AND USE OF IMPORTED BEDDING AND BACKFILL MATERIAL

\* TRENCH WIDTH INCLUDING TENCH BOX

DR. *AMB* DATE. 02/05/2020

CH. *TMJ*

APPROVED

*RWH*

SAINT PAUL REGIONAL WATER SERVICES  
CITY OF ST. PAUL, MN

WATER MAIN TRENCH DETAIL

STANDARD  
PLATE

D-5