



- IF AB IS LONGER THAN A STANDARD LENGTH OF PIPE, NO SLIP JOINT WILL BE ALLOWED.
- ALL OFFSETS SHALL BE RESTRAINED

WM SIZE	CD (STD. CIP)	CD (COMPACT DIP)
6"	5"	3"
8"	5.5"	3.5"
12"	7.5"	5.5"
16"	8"	5.5"

FOR RESTRAINED PIPE LENGTHS SEE PLATE D-11

\* INSULATION AND MIN. SEPARATION SHOWN BETWEEN WATER MAIN AND UTILITY APPLY TO STORM SEWER CROSSINGS ONLY. SEE SECTION 4570 FOR SEPARATION REQUIREMENTS FOR OTHER UTILITY CROSSINGS.