



REFER TO SECTION 3300 FOR ADDITIONAL REQUIREMENTS

LIQUID TEFLON OR TEFLON TAPE REQUIRED AT ALL THREADED FITTINGS.

LAWN SPRINKLER

SAME AS SERVICE EXCEPT:

- CURB STOP VALVE WITH DRAIN
- CURB STOP BURIED WITH 2'x2'x2' CLEAN 1 1/2" ROCK WRAPPED IN GEOTEXILE NONWOVEN FABRIC

DR. LJP DATE. 02/03/2023

CH. MGA

APPROVED

DJS

SAINT PAUL REGIONAL WATER SERVICES
CITY OF ST. PAUL, MN

TYPICAL 1", 1-1/2" AND 2" SERVICE
& LAWN SPRINKLER INSTALLATION

STANDARD
PLATE

D-13