



BOX CONSTRUCTION:

- NEWMA3R
- 1/8" ALUMINUM 5052-H32
- ANODIZED DURANODICS 313 BROWN
- NEOPRENÉ GASKET ON DOORS
- NON-CORRODING HARDWARE
- SERVICE ENTRANCE RATED
- ETL LISTED IN ACCORDANCE WITH UL50
- ETL LISTED IN ACCORDANCE WITH UL508A

I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota

Brian Vitek
 Brian Vitek

Date 11/16/15 Lic. No. 40444

APPROVED 11-16-15
Paul St. Mark
 For CITY ENGINEER

CITY OF ST. PAUL
 DEPARTMENT OF PUBLIC WORKS
METERED LIGHTING SERVICE - POLE MOUNT

Date of Revision
 OCT 2015

Standard Plate No.
5027B