



## CITY OF SAINT PAUL

DEPARTMENT OF SAFETY AND INSPECTIONS  
375 JACKSON STREET, SUITE 220  
ST. PAUL, MINNESOTA 55101-1806  
Phone: 651-266-8989 Fax: 651-266-9124  
Visit our Web Site at [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

## Residential Electrical Service Upgrades, Replacements, Etc.

For electrical service upgrades and change-outs, an Electrical Permit for a service must be purchased for \$78.00. This fee includes the service and all **existing** circuits/feeders that are reconnected to overcurrent devices installed as part of the replacement/upgrade. The fee will be increased \$13.00 per circuit for all **additional or modified** circuits/feeders installed as part of the project. The Property Maintenance Code is no longer enforced on this type of Electrical Permit.

All electrical service upgrades and replacements must meet the 2017 National Electrical Code (NEC). This includes, but is not limited to, service grounding and bonding, panelboard clearances, overhead service conductor clearances (existing or new), conduit/cable strapping (including existing service conduit), breaker ties/2-pole breakers for multi-wire circuits, grouping multi-wire circuit conductors, barriers at service terminations, and a completed circuit directory clearly identifying the use of each circuit and/or feeder.

If there is storm damage to a service mast an Electrical Permit must be purchased for the electrical service repair. The repairs to the service mast are required to meet the height requirements of Article 230.24(B), 2017 NEC. The Electrical Inspector will require access to the building to ensure the existing electrical service panel Grounding Electrode System has not been modified. If a service with an indoor meter is damaged and needs repair, contact Xcel Meters to determine whether they want the meter moved outside (this is entirely up to them, they have the right to refuse service if their requirements are not met). If you have any other questions please contact us at (651) 266-9003 **BEFORE** you start.

Thank you!