



Temporary Construction Trailers

Electrical Requirements


NEC 550.4 Mobile home not intended as dwelling



NEC 550.32 (A)
Maximum 30'
and within sight
not mounted
on trailer



NEC 550.32(A) Service rated disconnect



NEC 550-33 (A) Four insulated colored conductors



NEC 550.16 Separate neutrals from grounds and bond trailer frame to equipment ground bar in panel

NEC 250.53(A)(2) Two ground rods 6 feet apart



NEC 590.4(J) Cables used as feeders or branch circuits shall not be installed on the ground or floor